

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: YOUR TURN CONVENIENCE STOP
7505 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 15-02482

Last Inspected On: 7/17/2014

Operating Permit Renewal Date: 8/8/2017

Contact: Doug White, (406) 837-6170

Owners/Operators: White Enterprises, Owner (406)-837-6170 7505 MT HIGHWAY 35
BIGFORK MT 59911-6215

Angela Tull, UST Class A Operator
Alison Wallen, UST Class A Operator
Angela Tull, UST Class B Operator
Alison Wallen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	19	1/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3185			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		2/3/2011	TS-1000 , Incon		
7	19	1/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3186			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		2/3/2011	TS-1000 , Incon		
8	19	1/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3187			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		2/3/2011	TS-1000 , Incon		
9	18	11/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3188			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		2/3/2011	TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: MARINA CAY RESORT
180 VISTA DR
BIGFORK, MT 59911 FLATHEAD

Contact: Ronald Fetveit, (406) 837-5861

Sys Fac ID: 15-03002
Last Inspected On: 9/10/2015
Operating Permit Renewal Date: 10/14/2018

Owners/Operators: Elk LLC, Owner (406)-837-5861 PO BOX 709
BIGFORK MT 59911

Marina Cay Resort, Operator (406)-837-5861 PO BOX 663
BIGFORK MT 59911-0663

Mark Maliniak, UST Class A Operator

Mark Maliniak, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	16	5/5/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4067			None	Double-Walled	Yes
Temporarily Out of Use		5/1/2009	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					
3	08	7/25/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5110		9/8/2015	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: FLATHEAD LAKE LODGE
150 FLATHEAD LODGE RD
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 15-04551

Last Inspected On: 12/1/2015

Operating Permit Renewal Date:

Contact: Doug Averill, (406) 837-4391

Owners/Operators: Flathead Lake Lodge, Owner

(406)-837-3815 DOUG AVERILL
PO BOX 248
BIGFORK MT 59911-0248

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	5/14/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1826			None	None	Yes
Temporarily Out of Use		5/14/2002	Not Required	Safe Suction	Not Applicable
Gasoline		1/10/2013	Manual Tank Gauging, Tank Tightness Testing	Not Listed	
1,000					
2	21	6/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1827			None	None	Yes
Temporarily Out of Use		6/1/2004	Not Required	Safe Suction	Not Applicable
Gasoline		1/10/2013	Manual Tank Gauging, Tank Tightness Testing	Not Listed	
600					

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: KAY GB PROPERTIES LLC
8089 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 15-06086

Last Inspected On: 8/6/2014

Operating Permit Renewal Date:

Contact: (406) 250-2344

Owners/Operators: Kay G B Properties LLC, Owner (406)-250-2344 235 BLACK BEARLANE
BIGFORK MT 59911

Fred Burnham, UST Class A Operator

Kelly Johns, UST Class A Operator

Kelly Johns, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	24	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2283			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/20/2007			
7	24	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2284			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/20/2007			
8	24	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2285			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/20/2007			

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: KAY GB PROPERTIES LLC
8089 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Contact: (406) 250-2344

Sys Fac ID: 15-06086
Last Inspected On: 8/6/2014
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	21	3/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
2286			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		3/20/2007			

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: FERNDAL MARKET
1845 MT HIGHWAY 209
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 15-07199

Last Inspected On: 5/6/2014

Operating Permit Renewal Date: 8/8/2017

Contact: Jason Griggs, (406) 314-8234

Owners/Operators: Griggs Ferndale LLC, Owner (406)-837-5597 1845 MT HWY 209
BIGFORK MT 59911
Jason Griggs, Operator (406)-314-8234 965 SWAN RIVER RD
BIGFORK MT 59911
Ray Kleiv, UST Class A Operator
Ray Kleiv, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	39	4/28/1976	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3254			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
2	38	4/28/1977	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3255			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
3	22	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3256			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	22	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3257			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: ECHO LAKE STORE
110 SWAN RIVER RD
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 15-07361

Last Inspected On: 8/10/2015

Operating Permit Renewal Date:

Contact: Frances Forkin, (406) 837-4727

Owners/Operators: Forkins Echo Lake Store, Owner (406)-249-9043 135 MARKEN LOOP
BIGFORK MT 59911-6435

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	20	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3498			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		8/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			EECO 1500 , EMCO Electronics		
7	20	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3499			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		8/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
3,000			EECO 1500 , EMCO Electronics		
8	20	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3500			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		8/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
3,000			EECO 1500 , EMCO Electronics		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: CALUMET CARDLOCK
8111 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 15-09801

Last Inspected On: 1/7/2014

Operating Permit Renewal Date: 3/28/2017

Contact: Drew Pikes, (406) 249-1545

Owners/Operators: Bigfork Properties LLC, Owner (406)-837-4550 300 BRIDGE STREET
BIGFORK MT 59911
City Service Valcon LLC, Operator (406)-751-4640 PO BOX 1
KALISPELL MT 59903-0001
Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	34	5/1/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
481			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current, Galvanic
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	34	5/1/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
482			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current, Galvanic
Diesel		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	22	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
483			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: CALUMET CARDLOCK
8111 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 15-09801
Last Inspected On: 1/7/2014
Operating Permit Renewal Date: 3/28/2017

Contact: Drew Pikes, (406) 249-1545

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	20	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
484			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
5	20	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
485			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: EAGLE BEND YACHT HARBOR
371 EAGLE BEND DR
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 15-13152

Last Inspected On: 5/14/2013

Operating Permit Renewal Date: 6/1/2016

Contact: Dave Roberts, (406) 253-2840

Owners/Operators: Eagle Bend Yacht Harbor Boat Slip Owners Association, (406)-837-4536 PO BOX 463
Owner BIGFORK MT 59911-0463
Dave Roberts, Operator (406)-257-1302 WESTERN MOUNTAINS PROPERTY MANAGEMENT
ADDRESS UNKNOWN
MT

Sharla Ferron, UST Class A Operator
Jessica Glazier, UST Class A Operator
Edward Mitchke, UST Class A Operator
Jessica Glazier, UST Class B Operator
Edward Mitchke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	7/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4013			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
5,000		8/2/2010			
2	22	7/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4014			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
1,000		8/2/2010			

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: BIGFORK STAGE STOP INC
8263 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Contact: Steve Harris, (406) 837-1551

Sys Fac ID: 56-13885
Last Inspected On: 10/21/2013
Operating Permit Renewal Date: 12/6/2016

Owners/Operators: Bigfork Stage Stop Inc, Owner (406)-837-5858 PO BOX 243
BIGFORK MT 59911-0243

Ronald Brevik, UST Class A Operator
Alexander Olson, UST Class A Operator
Ronald Brevik, UST Class B Operator
Nancy Kitzenberg, UST Class B Operator
Alexander Olson, UST Class B Operator
Liana Rowe, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	17	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3531			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
2	17	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3532			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
3	17	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3533			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000					

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: Montana Ranch LLC
1463 HWY 83
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 60-15198

Last Inspected On: 1/15/2015

Operating Permit Renewal Date: 3/23/2018

Contact: Matt Cottle, (406) 253-8403

Owners/Operators: Montana Ranch LLC, Owner (406)-755-0264 1463 HWY 83
BIGFORK MT 59911
Matt Cottle, Operator (406)-253-8403 1463 HWY 83
BIGFORK MT 59911
Matt Cottle, UST Class A Operator
Matt Cottle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	04	8/29/2011	Fiberglass Reinforced Plastic	Steel	Ball Float Valve
5327			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
2,500		10/6/2011	Gilbarco EMC Basic , Gilbarco		Yes
2	04	8/29/2011	Fiberglass Reinforced Plastic	Steel	Ball Float Valve
5328			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
2,500		10/6/2011	Gilbarco EMC Basic , Gilbarco		Yes

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: JUNCTION GAS
7322 US HIGHWAY 2 E
COLUMBIA FALLS, MT 59912 FLATHEAD

Sys Fac ID: 15-02820
Last Inspected On: 11/19/2013
Operating Permit Renewal Date: 12/24/2016

Contact: Ramdeep Kaur, (406) 890-5047

Owners/Operators: RKR LLC, Owner (406)-890-5047 2100 US HWY 2 E
KALISPELL MT 59901
Aries Enterprises LLC, Operator (406)-890-5047 2100 US HWY 2 E
KALISPELL MT 59901
David M Brotnov, UST Class A Operator
Ramdeep Kaur, UST Class A Operator
Ramdeep Kaur, UST Class B Operator
Ramdeep Kaur, UST Class B Global Operator
Marlene Sevesind, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	38	7/1/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
496		1/25/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Gasoline		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000		6/29/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	38	7/1/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
497			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/31/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/5/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	38	7/1/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
498		1/25/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000		6/29/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: JUNCTION GAS
7322 US HIGHWAY 2 E
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Ramdeep Kaur, (406) 890-5047

Sys Fac ID: 15-02820
Last Inspected On: 11/19/2013
Operating Permit Renewal Date: 12/24/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	27	11/17/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
499			Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		7/31/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/13/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: COLUMBIA FALLS ALUMINUM CO LLC
2000 ALUMINUM DR
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Steve Wright, (406) 892-3261

Sys Fac ID: 15-04003
Last Inspected On: 11/28/2012
Operating Permit Renewal Date: 5/14/2016

Owners/Operators: Columbia Falls Aluminum Company LLC, Owner (406)-892-8211 2000 ALUMINUM DR
COLUMBIA FALLS MT 59912-9424

Stephen Wright, UST Class A Operator
Stephen Wright, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	26	7/18/1989	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
3413		11/28/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000					
9	26	7/18/1989	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
3415		11/28/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
3,000		11/20/2014			
10	26	7/18/1989	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
3414		11/28/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
5,000		11/20/2014			

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: MIKES OF COLUMBIA FALLS
1645 9TH ST W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Sean Hurley, (509) 535-7701

Sys Fac ID: 15-06839
Last Inspected On: 5/20/2014
Operating Permit Renewal Date: 7/31/2017

Owners/Operators: KMR LLC, Owner (406)-892-2078 1645 9TH ST W
COLUMBIA FALLS MT 59912

Mikes of Columbia Falls Inc, Operator (406)-892-2078 1645 9TH ST W
COLUMBIA FALLS MT 59912-4406

Ronda Heil, UST Class A Operator
Ronald May, UST Class A Operator
Michael W Robinson, UST Class A Operator
Joe Stenzel, UST Class A Operator
Jennifer Davis, UST Class B Operator
Kristy Stevenson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4466			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3366			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3367			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: MIKES OF COLUMBIA FALLS
 1645 9TH ST W
 COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Sean Hurley, (509) 535-7701

Sys Fac ID: 15-06839
Last Inspected On: 5/20/2014
Operating Permit Renewal Date: 7/31/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3368			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3369			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 1
502 9TH ST W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Roger Hovis, (406) 892-2245

Sys Fac ID: 15-08690
Last Inspected On: 1/16/2016
Operating Permit Renewal Date: 4/21/2019

Owners/Operators: Town Pump of Columbia Falls Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	34	7/14/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2420			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/13/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	30	10/1/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4380			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/13/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 1
502 9TH ST W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Roger Hovis, (406) 892-2245

Sys Fac ID: 15-08690
Last Inspected On: 1/16/2016
Operating Permit Renewal Date: 4/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	26	7/14/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4381			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/13/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	26	7/14/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2423			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/13/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: WILCO ENTERTAINMENT LLC
7356 US HIGHWAY 2 E
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Keith Brown, (406) 270-6530

Sys Fac ID: 15-11333
Last Inspected On: 4/20/2015
Operating Permit Renewal Date:

Owners/Operators: Wilco Entertainment LLC, Owner/Operator (406)-270-6530 PO BOX 701
LAKESIDE MT 59922

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
686			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	U.S. Suction	Galvanic
Gasoline		9/20/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/31/2008			
2	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
687			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	U.S. Suction	Galvanic
Gasoline		9/20/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/31/2008			
3	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
688			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	U.S. Suction	Galvanic
Gasoline		9/20/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/31/2008			
4	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
689			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	U.S. Suction	Galvanic
Diesel		9/20/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/31/2008			

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: CITY SERVICE VALCON
195 TRUCK ROUTE RD
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Corey Edens, (406) 755-6611

Sys Fac ID: 15-12972
Last Inspected On: 6/6/2014
Operating Permit Renewal Date: 10/2/2017

Owners/Operators: Valcon Distributing LTD, Owner (406)-755-6611 PO BOX 9200
Kary Tonjum, UST Class A Operator KALISPELL MT 59904-2200
Kary Tonjum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	12/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4404		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	
2	23	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4405		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	
3	23	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4406		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	
4	23	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4407		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: CITY SERVICE VALCON
195 TRUCK ROUTE RD
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Corey Edens, (406) 755-6611

Sys Fac ID: 15-12972
Last Inspected On: 6/6/2014
Operating Permit Renewal Date: 10/2/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	23	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4408		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 2
6102 US HIGHWAY 2 W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13825
Last Inspected On: 11/17/2015
Operating Permit Renewal Date: 11/19/2018

Owners/Operators: Columbia Falls Holdings LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, Ball Float Valve
2674			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, ELLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	18	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4670			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, ELLD Line Tightness Testing, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	18	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2676			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, ELLD Line Tightness Testing, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 2
6102 US HIGHWAY 2 W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13825
Last Inspected On: 11/17/2015
Operating Permit Renewal Date: 11/19/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	18	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2677			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, MLLD Line Tightness Testing, Approved Remote Monitoring	
10,000		11/12/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2678			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, MLLD Line Tightness Testing, Approved Remote Monitoring	
6,000		11/12/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	18	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2679		10/7/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, MLLD Line Tightness Testing, Approved Remote Monitoring	
6,000		11/12/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	15	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4249			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	15	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4250			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 2
 6102 US HIGHWAY 2 W
 COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13825
Last Inspected On: 11/17/2015
Operating Permit Renewal Date: 11/19/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	00	10/2/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5600		9/17/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
10	00	10/2/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5601		9/17/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in FLATHEAD County in the City of CORAM

Location: GLACIER CENTER
10049 US HIGHWAY 2 E
CORAM, MT 59913 FLATHEAD

Sys Fac ID: 15-10895

Last Inspected On: 5/28/2014

Operating Permit Renewal Date: 6/3/2017

Contact: Matt Kinsella, (406) 387-5090

Owners/Operators: High Altitude Enterprises Inc, Owner/Operator (406)-387-5090 PO BOX 130296
CORAM MT 59913-9060

Matt Kinsella, UST Class A Operator
ShariLyn Gronitz, UST Class B Operator
Matt Kinsella, UST Class B Operator
ShariLyn Gronitz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	27	4/17/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1883			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	20	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1884			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
6	20	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1885			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	20	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1886			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of HUNGRY HORSE

Location: BOBS GENERAL STORE
8930 US HIGHWAY 2 E
HUNGRY HORSE, MT 59919 FLATHEAD

Contact: Jeff Johnson, (406) 387-5504

Sys Fac ID: 15-07506
Last Inspected On: 3/5/2015
Operating Permit Renewal Date: 3/24/2018

Owners/Operators: Swiss Chalet Rentals, Owner (406)-387-5504 PO BOX 190010
HUNGRY HORSE MT 59919-0010

Robert Johnson, UST Class A Operator
Robert Johnson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	35	9/1/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4180			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		2/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		2/25/2015	TS-1001 , Incon		
2	35	9/1/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4181			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		2/25/2015	TS-1001 , Incon		
3	35	9/1/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4182			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/25/2015	TS-1001 , Incon		
4	35	9/1/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4183			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		2/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		2/25/2015	TS-1001 , Incon		

Facility Summary in FLATHEAD County in the City of HUNGRY HORSE

Location: CENEX ZIP TRIP #71
8840 US HIGHWAY 2 E
HUNGRY HORSE, MT 59919 FLATHEAD

Contact: Sean Hurley, (509) 535-7701

Sys Fac ID: 15-09708
Last Inspected On: 5/8/2014
Operating Permit Renewal Date: 7/31/2017

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Ronald May, UST Class A Operator
Michael W Robinson, UST Class A Operator
Joe Stenzel, UST Class A Operator
Andrew Duffie, UST Class B Operator
Justin Mace, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	27	5/2/1988	Cathodically Protected Steel	Steel	High Level Alarm
3239			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	27	5/2/1988	Cathodically Protected Steel	Steel	High Level Alarm
3240			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	27	5/2/1988	Cathodically Protected Steel	Steel	High Level Alarm
3241			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		3/19/2015	TLS-350/Gilbarco EMC , Veeder Root		
4	27	5/2/1988	Cathodically Protected Steel	Steel	High Level Alarm
3242			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: FLATHEAD ELECTRIC COOP KALISPELL
2510 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-00044

Last Inspected On: 4/8/2014

Operating Permit Renewal Date: 8/8/2017

Contact: Terry Tintzman, (406) 752-4483

Owners/Operators: Flathead Electric Coop, Owner (406)-751-4483 2510 US HIGHWAY 2 E
KALISPELL MT 59901-2397

Brenda Butler, UST Class A Operator
Terry Tintzman, UST Class A Operator
Brenda Butler, UST Class B Operator
Brent Senner, UST Class B Operator
Terry Tintzman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1090			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
5	17	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1091			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
6	17	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1092			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: EVERGREEN GAS & DELI
2100 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-00108
Last Inspected On: 11/17/2014

Operating Permit Renewal Date: 12/2/2017

Contact: Aries Enterprises LLC, (803) 522-5352

Owners/Operators: Aries Enterprises LLC, Owner/Operator (406)-890-5047 2100 US HWY 2 E
KALISPELL MT 59901
Ramdeep Kaur, UST Class A Operator
Ramdeep Kaur, UST Class B Operator
Ramdeep Kaur, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	6/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3180			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/20/2015			
5	17	6/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3181			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		3/20/2015			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KAL'S FOOD STORES #102
1090 N MERIDIAN RD
KALISPELL, MT 59901 FLATHEAD

Contact: (406) 554-4717

Sys Fac ID: 15-00110
Last Inspected On: 1/8/2016
Operating Permit Renewal Date: 3/23/2019

Owners/Operators: Brar Brothers LLC, Owner (559)-554-4717 1645 HWY 93 S SUITE K
KALISPELL MT 59901

Kals Food Stores Inc, Operator (559)-554-4717 1645 HWY 93 S SUITE K
KALISPELL MT 59901

Janelle Gentry, UST Class A Operator
Tiaja Hintz, UST Class A Operator
Ronda Mahaffy, UST Class A Operator
Tina Engebritson, UST Class B Operator
Janelle Gentry, UST Class B Operator
Tiaja Hintz, UST Class B Operator
Ronda Mahaffy, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	18	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3171			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/6/2016	Gilbarco EMC Basic , Gilbarco		
5	18	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3172			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		1/7/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		1/6/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KAL'S FOOD STORES #102
 1090 N MERIDIAN RD
 KALISPELL, MT 59901 FLATHEAD

Contact: (406) 554-4717

Sys Fac ID: 15-00110
Last Inspected On: 1/8/2016
Operating Permit Renewal Date: 3/23/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	18	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3173			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		1/6/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: APPLEWAY CONOCO
100 N MERIDIAN RD
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-00113

Last Inspected On: 3/10/2014

Operating Permit Renewal Date: 4/10/2017

Contact: James Cunningham, (406) 257-1732

Owners/Operators: Appleway Conoco, Owner (406)-257-1732 100 N MERIDIAN RD
KALISPELL MT 59901-3848

Jim Cuningham, UST Class A Operator

Jim Cuningham, UST Class B Operator

Jim Cuningham, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	36	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3141			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/6/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	36	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3142			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/6/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	36	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3143			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/6/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: WOODLAND QUIKSTOP
81 WOODLAND PARK DR
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-00115

Last Inspected On: 7/18/2013

Operating Permit Renewal Date: 12/6/2016

Contact: Scott E Curry, (406) 755-5075

Owners/Operators: Scott E Curry, Owner

(406)-755-5075

PO BOX 323

KALISPELL MT 59903-0323

Scott E Curry, UST Class A Operator

Scott E Curry, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	7/23/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3524			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000				Automatic Tank Gauging 0.2	
4	17	7/23/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3525			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000				Automatic Tank Gauging 0.2	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KALISPELL REGIONAL MEDICAL CENTER
325 CLAREMONT ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-00800

Last Inspected On: 12/3/2013

Operating Permit Renewal Date: 3/28/2017

Contact: Mark Chitwood, (406) 756-3695

Owners/Operators: Northwest Healthcare, Owner (406)-752-5111 ATTN MARK CHITWOOD AT PLANT OPERATIONS
310 SUNNYVIEW LN
KALISPELL MT 59901-3129

Mark Chitwood, UST Class A Operator
Steve Herman, UST Class A Operator
Kyle Hovey, UST Class A Operator
Steve Herman, UST Class B Operator
Kyle Hovey, UST Class B Operator
Mark Chitwood, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	25	11/6/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1465			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/12/2015			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CONOCO CAR CARE CENTER
292 3RD AVENUE EAST N
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-01677

Last Inspected On: 10/24/2014

Operating Permit Renewal Date: 12/12/2017

Contact: Lynn Tripp, (406) 755-3797

Owners/Operators: Valcon Distributing LTD, Owner (406)-755-6611 PO BOX 9200
KALISPELL MT 59904-2200

Shawn Norby, UST Class A Operator
Kary Tonjum, UST Class A Operator
Shawn Norby, UST Class B Operator
Kary Tonjum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	29	4/23/1986	Cathodically Protected Steel	No Piping	High Level Alarm
2202			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		3/30/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		4/25/2012	TLS-350/Gilbarco EMC , Veeder Root		
8	39	4/23/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2201			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		9/24/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/23/2014	TLS-350/Gilbarco EMC , Veeder Root		
9	44	4/24/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2199			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/24/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/23/2014	TLS-350/Gilbarco EMC , Veeder Root		
10	44	4/24/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2200			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/24/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/23/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CITY SERVICE VALCON LLC
52 5TH AVENUE WEST N
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-01680

Last Inspected On: 9/4/2013

Operating Permit Renewal Date: 11/1/2016

Contact: Kary Tonjum, (406) 755-4321

Owners/Operators: City Service Valcon LLC, Owner (406)-751-4640 PO BOX 1
KALISPELL MT 59903-0001
Drew Pike, UST Class A Operator
Drew Pike, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	17	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3689			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
25,000					
10	17	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3690			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
25,000					
11	17	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3691			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					
12	17	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3692			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CITY SERVICE VALCON LLC
52 5TH AVENUE WEST N
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-01680
Last Inspected On: 9/4/2013
Operating Permit Renewal Date: 11/1/2016

Contact: Kary Tonjum, (406) 755-4321

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
13	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3693			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KALS FOOD STORES #101
1645 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Contact: Michael Hayes, (406) 253-2458

Sys Fac ID: 15-02014

Last Inspected On: 12/17/2015

Operating Permit Renewal Date: 2/13/2019

Owners/Operators: Brar Brothers LLC, Owner

(559)-554-4717

1645 HWY 93 S SUITE K
KALISPELL MT 59901

Kals Food Stores Inc, Operator

(559)-554-4717

1645 HWY 93 S SUITE K
KALISPELL MT 59901

Kari Barnhouse, UST Class A Operator

Michael Hayes, UST Class A Operator

Ronda Mahaffy, UST Class A Operator

Ashley Anderson, UST Class B Operator

Stu Brickey, UST Class B Operator

Jimmy Bromgard, UST Class B Operator

Laura Cummings, UST Class B Operator

GORDON GUTHRIE, UST Class B Operator

Tiffany Howard, UST Class B Operator

Karen McLellan, UST Class B Operator

Alice Reeves, UST Class B Operator

ERICKA SCHAARSCHMIDT, UST Class B Operator

SHAWN SCHMIDT, UST Class B Operator

Tinisha Sederlin, UST Class B Operator

Tazarae Smith, UST Class B Operator

Jenny Tuck, UST Class B Operator

Jennifer Watt, UST Class B Operator

Cari Webb, UST Class B Operator

Kari Barnhouse, UST Class B Global Operator

Ashley Bloomfield, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KALS FOOD STORES #101
1645 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Contact: Michael Hayes, (406) 253-2458

Sys Fac ID: 15-02014
Last Inspected On: 12/17/2015
Operating Permit Renewal Date: 2/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	18	5/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
650			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
12	18	5/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
651			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
13	18	5/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
652			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
14	18	5/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
653			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MICHAELS EXXON
1011 US HIGHWAY 2 W
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-02330

Last Inspected On: 1/26/2015

Operating Permit Renewal Date: 3/31/2018

Contact: Michael Hayes, (406) 755-4075

Owners/Operators: Beargrass Holdings LLC, Owner (406)-752-5250 PO BOX 7505
KALISPELL MT 59904-0505

Michael Hayes, UST Class A Operator
Tiffany Howard, UST Class A Operator
Ashley Anderson, UST Class B Operator
Stu Brickey, UST Class B Operator
Jimmy Bromgard, UST Class B Operator
Laura Cummings, UST Class B Operator
Nicole Ferrari, UST Class B Operator
GORDON GUTHRIE, UST Class B Operator
Tiffany Howard, UST Class B Operator
Alice Reeves, UST Class B Operator
ERICKA SCHAARSCHMIDT, UST Class B Operator
SHAWN SCHMIDT, UST Class B Operator
Tinisha Sederlin, UST Class B Operator
Tazarae Smith, UST Class B Operator
Jenny Tuck, UST Class B Operator
Jennifer Watt, UST Class B Operator
Cari Webb, UST Class B Operator
Ashley Bloomfield, UST Class B Global Operator
Sherry Doyle, UST Class B Global Operator
Nicole Ferrari, UST Class B Global Operator
Tiffany Howard, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
15	23	12/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
654			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MICHAELS EXXON
1011 US HIGHWAY 2 W
KALISPELL, MT 59901 FLATHEAD

Contact: Michael Hayes, (406) 755-4075

Sys Fac ID: 15-02330
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
16	23	12/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
655			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
17	23	12/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
656			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/12/2015	TLS-350/Gilbarco EMC , Veeder Root		
18	22	4/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
657			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
19	22	4/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
658			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
20	22	4/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
659			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MICHAELS EXXON
1011 US HIGHWAY 2 W
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-02330
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/31/2018

Contact: Michael Hayes, (406) 755-4075

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
21	22	6/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
660			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ZIP TRIP 40
1420 1ST AVE E
KALISPELL, MT 59901 FLATHEAD

Contact: (406) 755-5713

Sys Fac ID: 15-02331
Last Inspected On: 1/9/2014
Operating Permit Renewal Date: 3/14/2017

Owners/Operators: CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Tom Savas, UST Class A Operator
Andrew Duffie, UST Class B Operator
Luci Tuttle, UST Class B Operator
Alex Henson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	4/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1303			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/7/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					
2	33	4/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1304			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/7/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					
3	33	4/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1305			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/7/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: DIAMOND AIRE LLC LEASEE
1893 AIRPORT RD
KALISPELL, MT 59901 FLATHEAD

Contact: (406) 752-5092

Sys Fac ID: 15-03172
Last Inspected On: 10/23/2013
Operating Permit Renewal Date: 12/20/2016

Owners/Operators: Montana Diamond Aire Inc, Owner (406)-752-5092 1893 AIRPORT RD
KALISPELL MT 59901-7501

John Talmage, UST Class A Operator
John Talmage, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	20	5/24/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3285		10/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
8	20	5/24/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3286		10/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ZIP TRIP 39
305 E IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-03915

Last Inspected On: 11/13/2015

Operating Permit Renewal Date: 3/30/2019

Contact: Jan Robison, (406) 755-3664

Owners/Operators: CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216
Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216
Pete Nussbaum, UST Class A Operator
Tom Savas, UST Class A Operator
Andrew Duffie, UST Class B Operator
Luci Tuttle, UST Class B Operator
Ian Johnstone, UST Class B Global Operator
Pete Nussbaum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1306			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	17	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1307			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ZIP TRIP 39
305 E IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-03915
Last Inspected On: 11/13/2015
Operating Permit Renewal Date: 3/30/2019

Contact: Jan Robison, (406) 755-3664

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	17	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1308			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
7	17	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1309			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: RMC KALISPELL SHOP
2214 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-04359

Last Inspected On: 4/15/2014

Operating Permit Renewal Date: 9/3/2017

Contact: Dave Stremel, (406) 752-4280

Owners/Operators: Rocky Mountain Contractors Inc, Owner (406)-752-4280 2214 US HIGHWAY 2 E
KALISPELL MT 59901-2816

Leona Prezeau, UST Class A Operator
Marvin Stone, UST Class A Operator
David Stremel, UST Class A Operator
Leona Prezeau, UST Class B Operator
Marvin Stone, UST Class B Operator
David Stremel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	22	1/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1284			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			Auto Stik II , EBW		
4	22	1/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1285			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			Auto Stik II , EBW		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: UNITED PARCEL SERVICE KALISPELL
1151 N MERIDIAN RD
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-04535
Last Inspected On: 4/17/2013
Operating Permit Renewal Date: 10/11/2016

Contact: Dave Stricker, (406) 755-7795

Owners/Operators: United Parcel Service, Inc, Owner (206)-621-6233 4455 7TH AVENUE S
SEATTLE WA 98108
United Parcel Service Plant Engineering Dept, Operator (206)-621-6261 4455 7TH AVE S
SEATTLE WA 98108
Robert Counts, UST Class A Operator
Trear Smith, UST Class A Operator
Russell Stott, UST Class A Operator
Paul Vandehey, UST Class A Operator
Robert Counts, UST Class B Operator
Russell Stott, UST Class B Operator
Trear Smith, UST Class B Global Operator
Paul Vandehey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	22	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2180			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
12,000		3/26/2013			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CLASSICAL GAS CHICKEN NOODLE
343 MAIN ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-04894

Last Inspected On: 10/30/2012

Operating Permit Renewal Date:

Contact: Margret Rowe, (949) 887-0254

Owners/Operators: Margret Watkins-Rowe, Owner/Operator

(406)-885-1127

420 WISCONSIN AVE
WHITEFISH MT 59937-2124

Lisa Shriver, UST Class A Operator

Lisa Shriver, UST Class B Operator

Lisa Shriver, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	20	9/14/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
438			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000					
4	20	9/14/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
439			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CHS - WEST
120 W IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-05069

Last Inspected On: 8/26/2014

Operating Permit Renewal Date: 1/14/2018

Contact: Ken Sederdahl, (406) 755-7400

Owners/Operators: CHS Inc - Kalispell, Owner (406)-755-7400 PO BOX 579
KALISPELL MT 59903
Ken Sederdahl, Operator (406)-755-7400 PO BOX 579
KALISPELL MT 59903
Victor Hannam, UST Class A Operator
Victor Hannam, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	3/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
868			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000		9/8/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
2	19	3/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
866			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		9/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
3	19	3/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
867			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		9/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: Warden Hutterian Brethren
295 MIDDLE RD
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-05344

Last Inspected On: 12/1/2015

Operating Permit Renewal Date: 2/12/2019

Contact: Steve Streich, (406) 253-2276

Owners/Operators: Warden Hutterian Brethren, Owner (406)-253-2276 1054 W HARDER RD
WARDEN WA 98857
Steve L Evans, UST Class A Operator
Steve L Evans, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
870			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/19/2015	Manual Tank Gauging	Deferred	
1,000					
2	20	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
869			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/19/2015	Manual Tank Gauging	Deferred	
1,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: WOODYS COUNTRY STORE INC
3333 MT HIGHWAY 35
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-05801

Last Inspected On: 2/19/2015

Operating Permit Renewal Date: 3/17/2018

Contact: Chuck Weis, (406) 755-5544

Owners/Operators: Woodys Country Store Inc, Owner

(406)-755-5544

3333 MT HIGHWAY 35
KALISPELL MT 59901-7724

Charles Weiss, UST Class A Operator

Charles Weiss, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	31	12/5/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2243			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			EECO 1500 , EMCO Electronics		
2	31	12/5/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2244			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			EECO 1500 , EMCO Electronics		
3	31	12/5/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2245			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		1/4/2012	EECO 1500 , EMCO Electronics		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KELLY RAES INC
25 BATAVIA LN
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-06101

Last Inspected On: 9/4/2013

Operating Permit Renewal Date: 10/26/2016

Contact: Jim Long, (406) 752-5880

Owners/Operators: Tab Young, Owner (406)-752-5880 25 BATAVIA LN
KALISPELL MT 59901-7280

Lisa Myers, UST Class A Operator
Marcie Riley, UST Class A Operator
Tab Young, UST Class A Operator
Dawn Brown, UST Class B Operator
Stephanie Brussels, UST Class B Operator
Tish Keck, UST Class B Operator
Lisa Meyers, UST Class B Operator
Lisa Myers, UST Class B Operator
Connie Parker, UST Class B Operator
Kayla Weisz, UST Class B Operator
Mona Woodruff, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	2/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4505			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/3/2013	Stat. Inventory Reconciliation	MLLD Line Tightness Testing	
6,000		9/3/2013			
4	51	1/1/1965	Bare Steel	Fiberglass Reinforced Plastic	
4506	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/3/2013	Deferred	MLLD Line Tightness Testing	
10,000		9/3/2013			
5	51	1/1/1965	Bare Steel	Fiberglass Reinforced Plastic	
4507	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/3/2013	Deferred	MLLD Line Tightness Testing	
8,000		9/3/2013			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: FLATHEAD COUNTY ROAD DEPT
1249 WILLOW GLEN DR
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-06286

Last Inspected On: 7/18/2013

Operating Permit Renewal Date: 11/18/2016

Contact: Ted Gilbertson, (406) 758-5790

Owners/Operators: Flathead County Commissioners, Owner (406)-758-5790 800 S MAIN ST
KALISPELL MT 59901-5435
Corey Pilsch, UST Class A Operator
Corey Pilsch, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	17	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1088		12/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
9	17	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1089		12/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
3,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ZIP TRIP 41
2490 US HIGHWAY 93 N
KALISPELL, MT 59901 FLATHEAD

Contact: Stephen Golleher, (406) 752-7555

Sys Fac ID: 15-07432
Last Inspected On: 7/16/2013
Operating Permit Renewal Date: 11/9/2016

Owners/Operators: CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Andrew Duffie, UST Class B Operator
Luci Tuttle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	4/23/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
382			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/17/2013			
2	30	4/23/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
383			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/17/2013			
3	13	6/21/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4685			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/17/2013			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: LANES FOOD AND FUEL
1454 MT HIGHWAY 35
KALISPELL, MT 59901 FLATHEAD

Contact: (406) 752-4962

Sys Fac ID: 15-08357
Last Inspected On: 6/12/2014
Operating Permit Renewal Date: 8/20/2017

Owners/Operators: Lanes Enterprises LLC, Owner (406)-756-0399 903 CONRAD DR
KALISPELL MT 59901-7802

Stephen Symington, UST Class A Operator
Stephen Symington, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	5/8/1982	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
1420			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/24/2014			
2	33	5/8/1982	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
1421			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/24/2014			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 1
445 W IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 15-08709
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 4/21/2019

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	4/14/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4679			Impressed Current	Double-Walled	Yes
Currently in Use		6/13/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/13/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	33	4/14/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2425			Impressed Current	None	Yes
Currently in Use		6/13/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/13/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	18	5/28/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff, Ball Float Valve
2426			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/13/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 1
445 W IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-08709

Last Inspected On: 1/19/2016

Operating Permit Renewal Date: 4/21/2019

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	18	5/28/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4680			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/13/2016	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
8	11	8/18/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4939			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/13/2016	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MDOT KALISPELL
85 5TH AVENUE EAST N
KALISPELL, MT 59901 FLATHEAD

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 15-08733
Last Inspected On: 6/26/2013
Operating Permit Renewal Date: 10/26/2016

Owners/Operators: MDOT Helena, Owner (406)-444-6200 KIM JANZEN
PO BOX 201001
HELENA MT 59620-1001

Joseph J Radonich, Operator (406)-444-9204 MDT
DEADHEAD
HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Walt Kerttula, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Paul Eggum, UST Class B Operator
Andrea Wyman, UST Class B Operator
Chance Guckenberger, UST Class B Global Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2892			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
10,000					
4	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2893			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
12,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: FLATHEAD COUNTY JUSTICE CENTER
920 S MAIN ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-09279

Last Inspected On: 10/9/2013

Operating Permit Renewal Date: 3/16/2017

Contact: Alan Marble, (406) 758-5561

Owners/Operators: Flathead County Commissioners, Owner

(406)-758-5790

800 S MAIN ST
KALISPELL MT 59901-5435

Don Mills, UST Class A Operator

Don Mills, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	28	3/11/1987	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
3810		10/9/2013	None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/14/2011	Automatic Tank Gauging 0.2		
6,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CHS - CENTRAL
55 4TH AVENUE EAST N
KALISPELL, MT 59901 FLATHEAD

Contact: Ken Sederdahl, (406) 755-7400

Sys Fac ID: 15-09705
Last Inspected On: 10/9/2014
Operating Permit Renewal Date: 3/9/2018

Owners/Operators: CHS Inc - Kalispell, Owner (406)-755-7400 PO BOX 579
KALISPELL MT 59903

Ken Sederdahl, Operator (406)-755-7400 PO BOX 579
KALISPELL MT 59903

Victor Hannam, UST Class A Operator
Victor Hannam, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	34	3/26/1981	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3786			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/14/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
2	34	3/26/1981	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3787			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/14/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
3	34	3/26/1981	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3788			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/14/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
8	16	3/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4075			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CHS - CENTRAL
55 4TH AVENUE EAST N
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-09705
Last Inspected On: 10/9/2014
Operating Permit Renewal Date: 3/9/2018

Contact: Ken Sederdahl, (406) 755-7400

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	16	3/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4076			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MICHEALS EAST
1278 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-09707

Last Inspected On: 5/27/2014

Operating Permit Renewal Date: 9/4/2017

Contact: Michael Hays, (406) 752-6299

Owners/Operators: Michaels East Inc, Owner/Operator (406)-752-6299 1278 HWY 2 EAST
KALISPELL MT 59901

Tiffany Howard, UST Class A Operator
Tiffany Howard, UST Class B Operator
Sherry Doyle, UST Class B Global Operator
Tiffany Howard, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	6/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3005			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	30	6/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3006			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	30	6/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3007			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000			TLS-350/Gilbarco EMC , Veeder Root		
4	30	6/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3008			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: BRIANS INC
1319 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Contact: Brian Kahler, (406) 755-7447

Sys Fac ID: 15-09820
Last Inspected On: 5/28/2014
Operating Permit Renewal Date: 6/28/2017

Owners/Operators: DJL LLC, Owner (406)-755-7447 PO BOX 9200
KALISPELL MT 59904-2200

Brian Kahler, UST Class A Operator
Brian Kahler, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	9/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1847			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/27/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		5/27/2014	TS-1000 , Incon		
2	20	9/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1848			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/27/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		5/27/2014	TS-1000 , Incon		
3	20	9/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1849			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/27/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,500		5/27/2014	TS-1000 , Incon		
4	20	9/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1850			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/27/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,500		5/27/2014	TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: WEST VALLEY SCHOOL DIST 1
2290 FARM TO MARKET RD
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-10295
Last Inspected On: 12/29/2014
Operating Permit Renewal Date: 12/31/2017

Contact: Todd A Fisk, (406) 755-7239

Owners/Operators: School Dist 1 West Valley, Owner (406)-755-7239 2290 FARM TO MARKET RD
KALISPELL MT 59901-7108
Phillip Jackson, UST Class A Operator
Phillip Jackson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	54	2/5/1962	Bare Steel	Steel	
			None	None	No
Temporarily Out of Use				Not Listed	
Heating Oil			Not Listed	Not Listed	
1,000					
2	20	8/9/1995	Fiberglass Reinforced Plastic	Copper	Flapper Valve (Auto Shutoff)
2249		7/23/2015	None	Secondary Containment Chase	Yes
Temporarily Out of Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Manual Tank Gauging	Not Listed	
1,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: RED EAGLE AVIATION INC
1880 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-11166

Last Inspected On: 10/24/2014

Operating Permit Renewal Date: 3/24/2018

Contact: Mike Strand, (406) 755-2376

Owners/Operators: Red Eagle Aviation Inc, Owner (406)-755-2376 1880 US HIGHWAY 93 S
KALISPELL MT 59903-0166
Paige Pitz, UST Class A Operator
Paige Pitz, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	35	1/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
4173			Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Aviation Gas		10/23/2014	Automatic Tank Gauging 0.2	Deferred	
12,000		11/28/2011	TS-1000 , Incon		
3	35	1/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
4144			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Aviation Gas		10/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		10/23/2014	TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: WHITE OAK MARKET INC
4810 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Contact: Howard Brearey, (406) 857-2344

Sys Fac ID: 15-13287
Last Inspected On: 8/25/2014
Operating Permit Renewal Date: 10/17/2017

Owners/Operators: White Oak of Montana LLC, Owner (406)-857-2344 4810 US HIGHWAY 93 S
KALISPELL MT 59901-7985

Amber Terrell, UST Class A Operator
Wendy Works, UST Class A Operator
Wendy Works, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	32	10/1/1983	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4481			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	32	11/1/1983	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4482			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	32	11/1/1983	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4483			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		5/27/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ARIES GAS AND GROCERY
7254 US HIGHWAY 93
KALISPELL, MT 59922 FLATHEAD

Sys Fac ID: 15-13487

Last Inspected On: 11/19/2013

Operating Permit Renewal Date: 12/6/2016

Contact: Ramdeep Kaur, (406) 890-5047

Owners/Operators: RKR LLC, Owner (406)-890-5047 2100 US HWY 2 E
KALISPELL MT 59901
Aries Enterprises LLC, Operator (406)-890-5047 2100 US HWY 2 E
KALISPELL MT 59901
Janet Heinze, UST Class A Operator
Steven Heinze, UST Class A Operator
Rod Phillips, UST Class A Operator
Janet Heinze, UST Class B Operator
Rod Phillips, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
669			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		6/27/2013	TS-2000 , Incon		
2	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
667			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		6/27/2013	TS-2000 , Incon		
3	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
668			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,000		6/27/2013	TS-2000 , Incon		
4	21	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
666			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		6/27/2013	TS-2000 , Incon		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: BRIANS C STORE
2075 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-13730

Last Inspected On: 11/14/2014

Operating Permit Renewal Date: 1/14/2018

Contact: Brian Kahler, (406) 755-7447

Owners/Operators: DJL LLC, Owner

(406)-755-7447

PO BOX 9200
KALISPELL MT 59904-2200

Brian Kahler, UST Class A Operator

Brian Kahler, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3353			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		9/10/2014		Continuous Interstitial Monitor	
2	19	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3354			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		9/10/2014		Continuous Interstitial Monitor	
3	19	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3357			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/10/2014		Continuous Interstitial Monitor	
4	19	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3355			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		9/10/2014		Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: BRIANS C STORE
2075 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-13730

Last Inspected On: 11/14/2014

Operating Permit Renewal Date: 1/14/2018

Contact: Brian Kahler, (406) 755-7447

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	19	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3356			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/10/2014		Continuous Interstitial Monitor	
6	19	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3352			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		9/10/2014		Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 3
2605 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-13732
Last Inspected On: 1/15/2016
Operating Permit Renewal Date: 5/7/2019

Contact: Doug Dodge, (406) 755-1306

Owners/Operators: Kalispell Holdings LLC, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-6000
Kalispell Holdings LLC, Operator	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator		
Trent Biggers, UST Class A Operator		
Don Edmisten, UST Class A Operator		
Daniel Sampson, UST Class A Operator		
Charles A Armstrong, UST Class B Global Operator		
Trent Biggers, UST Class B Global Operator		
Don Edmisten, UST Class B Global Operator		
Daniel Sampson, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4766		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4767		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 3
2605 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-13732
Last Inspected On: 1/15/2016
Operating Permit Renewal Date: 5/7/2019

Contact: Doug Dodge, (406) 755-1306

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4768		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4769		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	19	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4770		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 2
1100 E IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-13764
Last Inspected On: 1/18/2016
Operating Permit Renewal Date: 4/21/2019

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Kalispell Holdings LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4814			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	18	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4815			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	18	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4816			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 2
1100 E IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-13764

Last Inspected On: 1/18/2016

Operating Permit Renewal Date: 4/21/2019

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	18	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
4817			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4818			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 5
2910 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-13765

Last Inspected On: 9/29/2015

Operating Permit Renewal Date: 1/7/2019

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Main Street Holdings LLC, Owner (406)-497-6700 600 S MAIN ST
BUTTE MT 59701-2534

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3430			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
2	19	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3431			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
3	19	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3432			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	Yes
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CITY SERVICE BULK PLANT
1841 3RD AVE E
KALISPELL, MT 59901 FLATHEAD

Contact: Kary Tonjum, (406) 755-4321

Sys Fac ID: 56-13824
Last Inspected On: 9/4/2013
Operating Permit Renewal Date: 12/24/2016

Owners/Operators: City Service Inc, Owner (406)-755-4321 640 W MONTANA
KALISPELL MT 59901-5775

Drew Pike, UST Class A Operator
Drew Pike, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
681			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000					
2	18	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
682			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000					
3	18	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
683			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					
4	18	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
684			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CITY SERVICE BULK PLANT
1841 3RD AVE E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 56-13824

Last Inspected On: 9/4/2013

Operating Permit Renewal Date: 12/24/2016

Contact: Kary Tonjum, (406) 755-4321

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	18	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
685			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: HOLIDAY #722
840 W IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Contact: (952) 830-8899

Sys Fac ID: 56-13985
Last Inspected On: 11/4/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Rocky Mountain Oil Inc, Owner (952)-830-8700 ATTN: ENVIRONMENTAL DIRECTOR
4567 AMERICAN BLVD W
BLOOMINGTON MN 55437

Holiday #722, Operator (952)-830-8747 840 W IDAHO ST
KALISPELL MT 59901

Jason Cocke, UST Class A Operator
Robert Deninno, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Jeffrey Brown, UST Class B Operator
Jason Cocke, UST Class B Operator
John Collins, UST Class B Operator
Jason Cocke, UST Class B Global Operator
Mathew McConaughy, UST Class B Global Operator
Todd White, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	15	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4239			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		7/6/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	15	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4240			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/6/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: EAGLE FUELS LLC
3150 US HIGHWAY 2
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 56-14014

Last Inspected On: 11/18/2013

Operating Permit Renewal Date: 12/31/2016

Contact: Wayne Morgan, (406) 862-5422

Owners/Operators: Eagle Fuels LLC, Owner (406)-862-5422 1079 HODGSON RD
COLUMBIA FALLS MT 59912-9027
Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	14	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4605			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					
2	14	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4606			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					
3	14	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4607			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000					
4	14	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4608			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: FLATHEAD COUNTY SOLID WASTE DIST
4098 US HIGHWAY 93 N
KALISPELL, MT 59901 FLATHEAD

Contact: (406) 758-5918

Sys Fac ID: 56-14041
Last Inspected On: 7/18/2013
Operating Permit Renewal Date: 12/26/2016

Owners/Operators: Flathead County Commissioners, Owner (406)-758-5790 800 S MAIN ST
KALISPELL MT 59901-5435

James Chilton, UST Class A Operator
James Chilton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	14	11/26/2001	Fiberglass Reinforced Plastic	No Piping	Ball Float Valve
4559			Double-Walled	None	Yes
Currently in Use			Not Required	Not Listed	Not Applicable
Waste Oil					
1,000					
2	13	2/25/2003	Concrete	Flexible Plastic	
4802	Yes		None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
15,000					
3	13	2/25/2003	Concrete	Flexible Plastic	
4803	Yes		None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
3,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: SMITHS FUEL CENTER 172
195 3RD AVENUE WEST N
KALISPELL, MT 59901 FLATHEAD

Contact: (406) 752-5705

Sys Fac ID: 56-14062
Last Inspected On: 6/9/2014
Operating Permit Renewal Date: 11/4/2017

Owners/Operators: Smiths Food and Drug, Owner (801)-974-1529 1550 S REDWOOD RD
SALT LAKE CITY UT 84104-5105

Kerry Busey, UST Class A Operator
Michael D Crumley, UST Class A Operator
Gary Dotseth, UST Class A Operator
Todd Dotseth, UST Class A Operator
David Harris, UST Class A Operator
Todd Dotseth, UST Class B Operator
Kerry Busey, UST Class B Global Operator
Michael D Crumley, UST Class B Global Operator
Gary Dotseth, UST Class B Global Operator
David Harris, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	13	8/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4742			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	13	8/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4743			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: SMITHS FUEL CENTER 172
 195 3RD AVENUE WEST N
 KALISPELL, MT 59901 FLATHEAD

Contact: (406) 752-5705

Sys Fac ID: 56-14062
Last Inspected On: 6/9/2014
Operating Permit Renewal Date: 11/4/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	13	8/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4744			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: HEALTH CENTER NORTHWEST
320 SUNNYVIEW LN
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 56-14072

Last Inspected On: 12/3/2013

Operating Permit Renewal Date: 4/4/2017

Contact: Mark Chitwood, (406) 756-3695

Owners/Operators: Flathead Hospital Development Co, Owner

(406)-752-5111

ATTN PLANT OPERATIONS

320 SUNNYVIEW LN

KALISPELL MT 59901-3129

Mark Chitwood, UST Class A Operator

Steve Herman, UST Class A Operator

Kyle Hovey, UST Class A Operator

Steve Herman, UST Class B Operator

Kyle Hovey, UST Class B Operator

Mark Chitwood, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	12	12/16/2003	Concrete	Flexible Plastic	
4880	Yes	11/12/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
6,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: COSTCO WHOLESALE
2330 US HIGHWAY 93 N
KALISPELL, MT 59901 FLATHEAD

Contact: (406) 758-2500

Sys Fac ID: 60-15012
Last Inspected On: 6/9/2014
Operating Permit Renewal Date: 11/12/2017

Owners/Operators: Costco Wholesale, Owner (425)-313-8100 ATTN: LICENSING
PO BOX 35005
SEATTLE WA 98124-8990

Dennis Bock, UST Class A Operator
Trevor Eagleton, UST Class A Operator
David Ely, UST Class A Operator
Dan Martinez, UST Class A Operator
Michael Schaeffer, UST Class A Operator
Chuck Shillington, UST Class A Operator
Shawn Slack, UST Class A Operator
Trevor Eagleton, UST Class B Operator
David Ely, UST Class B Operator
Michael Williams, UST Class B Operator
Dennis Bock, UST Class B Global Operator
Michael Schaeffer, UST Class B Global Operator
Chuck Shillington, UST Class B Global Operator
Shawn Slack, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	10	10/7/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5033			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000		5/6/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	10	10/7/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5034			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000		5/6/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: COSTCO WHOLESALE
2330 US HIGHWAY 93 N
KALISPELL, MT 59901 FLATHEAD

Contact: (406) 758-2500

Sys Fac ID: 60-15012
Last Inspected On: 6/9/2014
Operating Permit Renewal Date: 11/12/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	10	10/7/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5035			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000		5/6/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	04	4/19/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5280			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Hazardous Substance			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,500		11/15/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in FLATHEAD County in the City of LAKESIDE

Location: ARSR GATR BLDG
BLACKTAIL MOUNTAIN RD
LAKESIDE, MT 59922 FLATHEAD

Sys Fac ID: 15-03618

Last Inspected On: 1/28/2015

Operating Permit Renewal Date: 2/19/2018

Contact: Larry Conrad, (406) 755-5499

Owners/Operators: Federal Aviation Admin Missoula, Owner

(406)-549-8300

4955 W BROADWAY ST
MISSOULA MT 59808-8706

Rob Jodsaas, UST Class A Operator

Rob Jodsaas, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	19	9/25/1996	Unknown	Flexible Plastic	
4565	Yes	12/8/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			Other , Other		

Facility Summary in FLATHEAD County in the City of LAKESIDE

Location: JOE BLOGZ
7170 US HIGHWAY 93 S
LAKESIDE, MT 59922 FLATHEAD

Sys Fac ID: 15-10513

Last Inspected On: 12/17/2015

Operating Permit Renewal Date: 2/20/2019

Contact: Rebecca King, (406) 844-3372

Owners/Operators: Cruiser LLC, Owner/Operator (406)-844-3372 PO BOX 225
LAKESIDE MT 59922
Robert C Lincoln, UST Class A Operator
Robert C Lincoln, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	3/7/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3798			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use		1/1/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/22/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	30	3/7/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3799			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use		1/1/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/22/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of LAKESIDE

Location: DR VAN KIRKE NELSON
616 LUTHERAN CAMP RD
LAKESIDE, MT 59922 FLATHEAD

Sys Fac ID: 56-14069

Last Inspected On: 10/9/2014

Operating Permit Renewal Date: 2/19/2018

Contact: (406) 752-5252

Owners/Operators: Van Kirke Nelson, Owner

PO BOX 1175
KALISPELL MT 59903

Greg Nelson, UST Class A Operator
Van Kirke Nelson, UST Class A Operator
Greg Nelson, UST Class B Operator
Van Kirke Nelson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	13	12/30/2002	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4781		10/9/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Manual Tank Gauging	Continuous Interstitial Monitor	
800			ILS-350 , Veeder Root		

Facility Summary in FLATHEAD County in the City of MARION

Location: MOOSE CROSSING INC
8405 US HIGHWAY 2 W
MARION, MT 59925 FLATHEAD

Contact: (406) 854-2070

Sys Fac ID: 15-10015
Last Inspected On: 5/15/2013
Operating Permit Renewal Date: 10/26/2016

Owners/Operators: Vern Taber Moose Crossing Inc, Owner (406)-854-2070 8405 US HIGHWAY 2 W
MARION MT 59925-9701

Rebecca Taber, UST Class A Operator
Vern Taber, UST Class A Operator
Rebecca Taber, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	18	9/25/1997	Unknown	Flexible Plastic	
1245	Yes	1/25/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
4,000					
4	18	9/25/1997	Unknown	Flexible Plastic	
1246	Yes	1/25/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
3,000					
5	18	9/25/1997	Unknown	Flexible Plastic	
1247	Yes	1/25/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
1,000					

Facility Summary in FLATHEAD County in the City of MARION

Location: CANI INC
8205 US HIGHWAY 2 W
MARION, MT 59925 FLATHEAD

Sys Fac ID: 56-13803

Last Inspected On: 9/19/2013

Operating Permit Renewal Date: 11/6/2016

Contact: Tonia May, (406) 854-2992

Owners/Operators: CANI Inc, Owner

(406)-854-2992

PO BOX 9633

KALISPELL MT 59904-2633

Tonia Gardner, UST Class A Operator

Tonia Gardner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	8/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
834			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/19/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000					
2	18	8/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
835			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/19/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000					
3	18	8/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
836			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/19/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000		2/12/2015			

Facility Summary in FLATHEAD County in the City of MARION

Location: CABIN CREEK LANDING LLC
166 WRIGHT WAY
MARION, MT 59925 FLATHEAD

Sys Fac ID: 56-14102

Last Inspected On: 3/21/2014

Operating Permit Renewal Date: 4/4/2017

Contact: Russell Olsen, (406) 752-0051

Owners/Operators: Cabin Creek Landing LLC, Owner

(406)-752-0051

2820 HELENA FLATS RD
KALISPELL MT 59901-6535

Russell Olsen, UST Class A Operator

Russell Olsen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	12	2/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4883		3/21/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of OLNEY

Location: GLACIER GOLD LLC
255 GOOD CREEK RD
OLNEY, MT 59927 FLATHEAD

Sys Fac ID: 15-02973

Last Inspected On: 4/16/2015

Operating Permit Renewal Date:

Contact: (406) 881-3033

Owners/Operators: Glacier Gold LLC, Owner

(406)-881-3030

PO BOX 128
OLNEY MT 59927-9999

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	27	3/29/1988	Cathodically Protected Steel	No Piping	
3583			None	None	Yes
Temporarily Out of Use				Pressurized	Galvanic
Gasoline		5/11/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Vapor Monitoring		
9,000					

Facility Summary in FLATHEAD County in the City of OLNEY

Location: OLNEY STORE
105 OLNEY LOOP RD
OLNEY, MT 59927 FLATHEAD

Contact: Fred Peters, (406) 881-9988

Sys Fac ID: 56-13849
Last Inspected On: 7/2/2013
Operating Permit Renewal Date: 9/17/2016

Owners/Operators: Fred Peters, Owner	(406)-881-9988	PO BOX 1208 COLUMBIA FALLS MT 59912
Donna Briggs, Operator	(406)-881-2009	9 RR STREET OLNEY MT 59927
Reggie Briggs, Operator	(406)-881-2009	9 RR STREET OLNEY MT 59927
Donna M Briggs, UST Class A Operator		
Sandra Mayert, UST Class A Operator		
Donna M Briggs, UST Class B Operator		
Sandra Mayert, UST Class B Operator		
Ruth Prince, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3504			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/26/2013	Automatic Tank Gauging 0.2	Not Listed	
1,000					
4	17	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3505			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/26/2013	Automatic Tank Gauging 0.2	Not Listed	
500					
5	17	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3506			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/26/2013	Automatic Tank Gauging 0.2	Not Listed	
500					

Facility Summary in FLATHEAD County in the City of POLEBRIDGE

Location: HOME RANCH STORE
8950 N FORK RD
POLEBRIDGE, MT 59928 FLATHEAD

Sys Fac ID: 15-12800
Last Inspected On: 3/30/2015

Operating Permit Renewal Date:

Contact: Gregory Puckett, (513) 505-5716

Owners/Operators: Mountain Fever LLC, Owner/Operator (406)-888-5572 8950 NORTH FORK RD
POLEBRIDGE MT 59928

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	6/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2978			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		5/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000					

Facility Summary in FLATHEAD County in the City of WEST GLACIER

Location: MRC GAS STATION
200 GOING TO THE SUN RD
WEST GLACIER, MT 59936 FLATHEAD

Contact: Ron Behney, (406) 892-6705

Sys Fac ID: 15-03288
Last Inspected On: 9/27/2014
Operating Permit Renewal Date: 12/2/2017

Owners/Operators: Glacier Park INC, Owner/Operator (620)-207-1077 1850 NORTH CENTRAL AVENUE SUITE 1900
PHOENIX AZ 85004

Charles Krasselt, UST Class A Operator
Richard Kreienheder, UST Class A Operator
Cassandra Pyles, UST Class A Operator
Richard Kreienheder, UST Class B Operator
Cassandra Pyles, UST Class B Operator
Charles Krasselt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	26	10/23/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2246			Double-Walled	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/10/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
10,000		9/10/2014	TLS-300 , Veeder Root		
5	26	10/23/1989	Cathodically Protected Steel	No Piping	Ball Float Valve
2247			Double-Walled	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/10/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		9/10/2014	TLS-300 , Veeder Root		
6	26	10/23/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2248			Double-Walled	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/10/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
6,000		9/10/2014	TLS-300 , Veeder Root		

Facility Summary in FLATHEAD County in the City of WEST GLACIER

Location: GLACIER PARK HDQTRS GAS PUMPS
 PO BOX 128
 WEST GLACIER, MT 59936 FLATHEAD

Contact: Del Zimmerli, (406) 888-7978

Sys Fac ID: 15-09491
Last Inspected On: 5/29/2014
Operating Permit Renewal Date: 8/2/2017

Owners/Operators: Glacier National Park, Owner (406)-732-7718 PO BOX 128
 WEST GLACIER MT 59936-0128

Lori King, UST Class A Operator
 Franklin Thompson, UST Class A Operator
 Lori King, UST Class B Operator
 Franklin Thompson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	25	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1219		12/12/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		5/28/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					
6	25	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1220		12/12/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					

Facility Summary in FLATHEAD County in the City of WEST GLACIER

Location: GLACIER HIGHLAND RESORT
US 12555 HIGHWAY 2 E
WEST GLACIER, MT 59936 FLATHEAD

Sys Fac ID: 15-10685

Last Inspected On: 5/29/2014

Operating Permit Renewal Date: 9/17/2017

Contact: Joe Hoff, (406) 888-5427

Owners/Operators: Glacier Highland Resort, Owner (406)-888-5427 PO BOX 397
WEST GLACIER MT 59936-0397
Joe Hoff, UST Class A Operator
Joe Hoff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3214			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/25/2013	EECO 1500 , EMCO Electronics		
4	17	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3215			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		9/25/2013	EECO 1500 , EMCO Electronics		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: WESTSIDE EXXON
145 2ND ST W
WHITEFISH, MT 59937 FLATHEAD

Sys Fac ID: 15-00112

Last Inspected On: 4/16/2015

Operating Permit Renewal Date: 9/6/2018

Contact: Frank Barnes, (406) 862-4556

Owners/Operators: Barnes Enterprises Inc, Owner (406)-862-4535 PO BOX 4269
WHITEFISH MT 59937-4269
Franklin Barnes, UST Class A Operator
Franklin Barnes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	19	11/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3421			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000			TLS-300 , Veeder Root		
4	19	11/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3422			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000			TLS-300 , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: CENEX ZIP TRIP #69
6585 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD

Sys Fac ID: 15-04903
Last Inspected On: 10/21/2013
Operating Permit Renewal Date: 12/27/2016

Contact: Ian Johnstone, (509) 535-7701

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216

Ronald May, UST Class A Operator
Michael W Robinson, UST Class A Operator
Joe Stenzel, UST Class A Operator
Andrew Duffie, UST Class B Operator
Suzan Hughes, UST Class B Operator
Justin Mace, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	24	11/4/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2956			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/7/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000					
8	24	11/4/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2957			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/7/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000					
9	24	11/4/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2958			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/7/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000					
10	24	11/4/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2959			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/7/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: BIG MOUNTAIN SKI RESORT SHOP
3910 BIG MOUNTAIN RD
WHITEFISH, MT 59937 FLATHEAD

Sys Fac ID: 15-05579

Last Inspected On: 8/27/2013

Operating Permit Renewal Date: 10/22/2016

Contact: Bob Yeager, (406) 862-1989

Owners/Operators: Winter Sports Inc, Owner

(406)-862-2987

PO BOX 1400

WHITEFISH MT 59937-1400

Rory Kizer, UST Class A Operator

Rory Kizer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	23	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2295			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/25/2013			
9	17	7/14/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2296			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
12,000		11/1/2006			
10	17	7/14/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2297			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
2,000		11/1/2006			

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: MIDWAY MINI MART
4899 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD

Contact: Dan Scheffer, (406) 862-1451

Sys Fac ID: 15-07766
Last Inspected On: 3/20/2014
Operating Permit Renewal Date: 8/7/2017

Owners/Operators: Daniel Scheffer, Owner (406)-862-1451 818 BOULDER LN
WHITEFISH MT 59937-3233

Daniel Scheffer, UST Class A Operator
Daniel Scheffer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	19	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3384			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		10/25/2010	TLS-350/Gilbarco EMC , Veeder Root		
5	19	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3385			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,000		1/13/2010	TLS-350/Gilbarco EMC , Veeder Root		
6	19	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3386			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		1/14/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: TOWN PUMP INC WHITEFISH 2
6600 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD

Sys Fac ID: 15-10105
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 4/21/2019

Contact: Kevin Kenneally, (406) 862-7204

Owners/Operators: Troy Town Pump Inc, Owner	(406)-497-6700	600 S MAIN ST BUTTE MT 59701-2534
Troy Town Pump Inc, Operator	(406)-497-6700	600 S MAIN ST BUTTE MT 59701-2534
Charles A Armstrong, UST Class A Operator		
Trent Biggers, UST Class A Operator		
Don Edmisten, UST Class A Operator		
Daniel Sampson, UST Class A Operator		
Charles A Armstrong, UST Class B Global Operator		
Trent Biggers, UST Class B Global Operator		
Don Edmisten, UST Class B Global Operator		
Daniel Sampson, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	26	1/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2428			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	26	1/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4306			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: TOWN PUMP INC WHITEFISH 2
6600 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD

Contact: Kevin Kenneally, (406) 862-7204

Sys Fac ID: 15-10105
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 4/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	26	1/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2430			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
4	26	1/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2431			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	11	10/1/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4941			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: ALPINE VILLAGE MARKET
721 WISCONSIN AVE
WHITEFISH, MT 59937 FLATHEAD

Sys Fac ID: 15-10944
Last Inspected On: 9/12/2014
Operating Permit Renewal Date: 12/31/2017

Contact: Alan Reisch, (406) 862-5025

Owners/Operators: Super Grocer Corp, Owner/Operator (406)-862-5025 721 WISCONSIN AVE
WHITEFISH MT 59937

Alan Reisch, UST Class A Operator
Brent Silcox, UST Class A Operator
Alan Reisch, UST Class B Operator
Brent Silcox, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	34	4/21/1981	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4692			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/12/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		9/10/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
2	34	4/21/1981	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4693			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/12/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		8/15/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
3	24	10/1/1991	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4694			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/12/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		8/2/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: WHITEFISH LAKE LODGE
1399 WISCONSIN AVE
WHITEFISH, MT 59937 FLATHEAD

Sys Fac ID: 15-12719

Last Inspected On: 7/23/2014

Operating Permit Renewal Date: 9/29/2017

Contact: Will Stock, (406) 863-4043

Owners/Operators: Whitefish Lake Lodge, Owner

(406)-837-7050

DAN AVERILL CFO
PO BOX 2040
WHITEFISH MT 59937-2040

Chris Gulick, UST Class A Operator
Heath Howell, UST Class A Operator
Chris Gulick, UST Class B Operator
Heath Howell, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	23	4/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4898		8/25/2014	Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		7/22/2014	Other , Other		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: NORTH VALLEY HOSPITAL
1600 HOSPITAL WAY
WHITEFISH, MT 59937 FLATHEAD

Sys Fac ID: 60-15034

Last Inspected On: 5/14/2013

Operating Permit Renewal Date: 9/6/2016

Contact: Joe Grabowski, (406) 862-2501

Owners/Operators: North Valley Hospital, Owner

(460)-863-3561

JOE GRABOWSKI
1600 HOSPITAL WAY
WHITEFISH MT 59937-2990

Joseph Grabowski, UST Class A Operator

Joseph Grabowski, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	09	1/17/2007	Aboveground Tank	Flexible Plastic	
5123	Yes	5/14/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Heating Oil			Deferred	Continuous Interstitial Monitor	
4,000					

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: SAFEWAY FUEL STATION #2106
110 WEST 13TH ST
WHITEFISH, MT 59937 FLATHEAD

Contact: Randy Bebee, (406) 862-3006

Sys Fac ID: 60-15151
Last Inspected On: 7/16/2013
Operating Permit Renewal Date: 12/28/2016

Owners/Operators: Safeway# 2106, Owner (623)-869-3573 PO BOX 29096 MS 6531
PHOENIX AZ 85038-9096

Aaron Nelson, Operator (425)-201-6301 1121 124TH AVE NE
BELLEVUE WA 98005-2101

Aaron Nelson, UST Class A Operator
Lynn Pehrson, UST Class A Operator
Debbie Dull, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	05	4/28/2010	Bare Steel	Flexible Plastic	High Level Alarm
5233			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					Yes
2	05	4/28/2010	Bare Steel	Flexible Plastic	High Level Alarm
5234			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					Yes
3	05	4/28/2010	Bare Steel	Flexible Plastic	High Level Alarm
5235			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					Yes